

V4





Energy Efficiency for Green Data Centers System z9 Typical KW



Green z Consultant

dfa@us.ibm,com (845) 435-6168

© 2007 IBM Corporation


Green z

October 2007




Power and cooling "Measured" / Typical values

- Examples of Server actually measured System z
- Average = typical
 - Hourly average (TYPICAL)
 - Hourly min and max
- Field population of GA3 z9 BC and z9 EC
 - By model for hundreds and eventually thousands of servers
 - Typical # is exactly what is needed for energy decisions



ENERGY LABEL 能源標欄		
Brand as p Model site		ABC X.VM HK1234
Array Fring, Careson a 117,418 http://www.careson.com	a hotel	1200
Energy Differency State R. B. Nog (19) Angle Ingene State State States 1, 1994		1
Rosen Gaster Garegare 1 Dontrie Gases for 1970 Rologana 1	12/0811 2-14 3-14	15 15
Mis Republic Partie		d motors






Pader 6 New VECCHO Pro parent D. Holdson of the application to make maintains in her chart in Obscury group before internation respecting the efficiency can be international in the application. Apr to the international

THE R. P. LEWIS CO., NAME AND ADDRESS OF TAXABLE PARTY.

-

z9 BC Maximum average hourly power consumption for th month of 8/2007 - excludes '0' samples 290 Systems at GA3 code levels



R07

S07



Typical Energy Consumption System z9 BC (KW)

System z9 BC	Model R07	Model S07
ĸw		
Мах	3.5	3.5
Typical 90%	3.0	3.5
Typical 50%	2.5	2.5

Based on field data August and Sept. 2007


+90% of measured systems within average of hourly averages

+50% of measured systems within average of hourly averages

Not even one of the Systems at or near label power, 5.3 KW

© 2007 IBM Corporation

z9 EC Average average hourly power consumption for the month of 8/2007 - excludes '0' samples 374 Systems at GA3 code levels





Typical Energy Consumption System z9 EC (KW)

System z9 EC model	S08	S18	S28	S38 / S54
KW				
Max	9	12	12	14
Typical 90%	6	9	12	13
Typical 50%	4	7	10	11
Pocod on field	data August an	d Sopt 2007		
Based on field data August and Sept. 2007 No system at max label rating of 18.3 KW				
+90% of measured systems within average of hourly averages				
+90% of measured systems within average of nourly averages				

+50% of measured systems within average of hourly averages

© 2007 IBM Corporation



Typical Energy Consumption System z9 EC S54 (KW)

System z9 EC	S54
Max	15
Typical 90%	13
Typical 50%	11

Based on Field Data August and Sept. 2007

No system at label power 18.3 KW

IBM STG



EPA Report to Congress on data center energy efficiency is consistent with the IBM five steps to a green data center

Scenario	IT Equipment	Site Infrastructure (Power and Cooling)
Improved operation 20% Energy Savings 	 Continue current trends for server consolidation Eliminate unused servers Adopt "energy-efficient" servers to modest level Enable power management on 100% of applicable servers Assume modest decline in energy use of enterprise storage equipment 	30% improvement in infrastructure energy efficiency from improved airflow management
Best practice • 45% Energy Savings	 All measures above plus: Consolidate servors to moderate extent Aggressively adopt "energy-efficient" servers Assume moderate storage consolidation 	 Up to 70% improvement in infrastructure energy efficiency from all measures in "Improved operation scenario, plus: Improved transformers and uninterruptible power supplies Improved efficiency chillers, fans, and pumps Free cooling
State-of-the- art • 55% Energy Savings	 All measures above plus: Aggressively consolidate servers Aggressively consolidate storage Enable power management at data center level of applications, servers, and equipment for networking and storage 	Up to 80% improvement in infrastructure energy efficiency, due to all measures in "Best practice" scenario, plus: Direct liquid cooling Combined heat and power

Source: EPA Response to Congress for Public Law 100-431, 08/07/07. See page 53 for more details.

Gartner's list of Top Ten Technologies for 2008

The Top 10 Technologies




Web Platform

Mashups

Computing Fabrics

Social Software

Real World Web



Why Green IT is #1

- 2006 many technical barriers and limitations were overcome.
- 2007 moved from a niche to widespread adoption.
- 2008 business are planning new and revised approach to green.

© 2007 IBM	4/9/2008	10
Corporation		











Barriers to Energy Efficiency and How you can set Goals

- 1. Defining Efficiency (same or better service with less energy)
- 2. First Cost (Up front costs vs. investing for payback over time)
- 3. Split Incentives (who pays electric bill / who invests capital)
- 4. Risk Aversion (security and interrupted operations / measurements and incentives)
- 5. Learning Curve (running equipment vs. equipment running energy efficient)
- 6. Quickly Changing Technology (IT vs. HVAC mismatch)
- 7. Lack of Energy Monitoring (collecting data on components for improving efficiencies, actively managing or charge back)

Source EPA Report p.84 - 89

Customer Example of Year end 2008 Goals

- **1.** Energy Consumption Reduce 10%
- 2. Server room reduction 40%
- **3.** IT resources ROHS compliant achieve 30%
- 4. Dispose of resources (through Green process) 25%
- 5. Educate/Certify Staff 5%
- 6. Improve Energy Efficiency 20%





Potential Energy Efficiency Opportunities Table 3-6

- Computing software Design software to avoid excess code and inefficienciestreat CPU cycles as a finite resource) Provide developer tools to help improve efficiency of software Enable shifting of computational load among systems for maximizing energy efficiency Upgrade applications no longer supported on latest technology and/or operating systems, allowing removal of legacy servers Implement virtualization to allow consolidation of server and storage hardware
- IT hardware (computing, storage and network) Operational Improvements Turn off (ideally remove) dead, obsolete, or excess equipment Turn off or power-manage equipment that won't be used for extended periods of time (e.g., development systems not in active use, systems for future expected increases in activity, etc.) Enable power-management features on existing equipment (e.g., frequencyvoltage scaling) Maximize utilization of storage capacity through shared data storage, data compression, and data de-duplication Accept high-efficiency power supplies over full operating range including DC-DC conversions) or directly accept moderate DC voltage Digitally control power supplies to better match output to load Use high-efficiency variable speed fans (within IT equipment) Reduce energy use at lower utilizations (whether the resource is processing capacity, memory, communications, or etc.). Applies to individual systems and to clusters. Improve microprocessors to lower leakage current, increase system integration, etc. Use storage virtualization and massive array of idle disks (MAID) technologies to allow storage power Use centralized servers (large systems to improve sharing of computer resources Improve hardware support for virtualization Use built-in power monitoring
- Electrical Systems Use high-efficiency power distribution (i.e., higher-voltage AC or moderatevoltage DC (50-600 VDC)) Use premium-efficiency motors in fans and pumps Use high-efficiency UPS units over full range of load Use rotary-based UPS units Right size power distribution and conversion to optimize efficiency Use on-site generation with grid as back-up




Potential Energy Efficiency Opportunities Table 3-6 continued

- Heat Removal Improve airflow management (i.e., use hot/cold aisle configuration or penetration sealing) Adjust environmental conditions (temperature and humidity set points) to allow wider range while still meeting manufacturer specifications Optimize data center airflow configuration using visualization tools (computational fluid dynamics modeling or infrared tomographyUse highefficiency variable-speed air-handler fans and chilled water pumps Use variable-speed chillers Use variable-speed, primary-only chilled water pumping Use high-efficiency chiller and chilled water supply motors Use high-efficiency CRAC units Use air-side economizers (outdoor air) when outdoor conditions permit (preferably in mild climate locations) 54 (operation)) (server count Use water-side economizers (cooling tower) when outdoor conditions permit (preferably in mild climate locations) Commission infrastructure systems to ensure set points are at proper values, sensors are in calibration, airflow is within design tolerances, etc. Rebalance air-handler system after significant IT reconfiguration Size systems and configure redundancy to maximize efficiency e.g., use redundant air-handler capacity in normal Increase chilled water supply and return temperature difference to reduce chilled water flow Optimize chilled water plant (cooling tower) Reuse waste heat for space heating Use direct liquid cooling (water or other dielectric liquid with currently available technology.e., in-rack or in-row cooling) and emerging technology (i.e., in-chassis or chip-level)
- Controls and Management Use system management hardware/software that enables powering down (to sleep and/or off) parts of server clusters during times of low utilization Dispatch non-time-sensitive computational operations to reduce peak computing load and allow reduction of total Provide for standard reporting of power use, platform temperature, and processor utilizations to assist operators in understanding and managing energy use in their data centers Use shared computing models, such as grid computing Optimize cooling controls to dynamically match the cooling supply to the IT heat load Dynamically optimize the assignment of work across the data center to ensure maximum efficiency Monitor power in real time
- Distributed Generation Use combined heat and power Use renewable energy (e.g., photovoltaic panels) Use fuel cells

*Each opportunity is not necessarily applicable to all data centers © 2007 IBM Corporation





Environmental



Corporate social responsibility image Meaningful energy conservation

- Improved public image
- Positive contribution to the Green movement creates a good place to work

Lack public image

Improve employee moral